

805553

**CO capsule for Multi-stimulus detector tester 805551**

Replacement CO capsule (Testfire TC3) for the testing of detectors with carbon monoxide sensors (CO). Especially suited for the IQ8Quad OTG multisensor detector 802473 (with CO sensor). Suitable for the multi-stimulus detector tester 805551.



The IQ8Quad OTG multisensor detector (CO) 802473 is generally tested either
-with the test gas 060430.10, suitable for the smoke detector tester 805582, or
-with 805552, suitable for the multi-stimulus detector tester 805551.

The 802473 is VdS-approved as a smoke detector, the CO test gas is required for the additional triggering of the electrochemical CO gas cell.

Features

- Non-flammable CO activating material
- Generation of small amounts of CO
- Generation of CO during testing only
- No storing of pressurized CO - no dangerous goods
- More productivity than the spray can

805582

**Smoke detector tester**

The smoke detector tester is designed for electric function control for the IQ8Quad and series 9x00 detectors. After an aerosol has been released, the operation capacity of the measuring chamber can be tested by using the transceiver. The smoke detector tester is adapted to the rod (Part No. 060427).



The telescopic rod is not supplied as standard.

Accessories

060426 Plastic telescopic extension
060427 Plastic telescopic rod

060430.10

**Test gas for smoke detector tester 805582**

For IQ8Quad and series 9x00 detectors, suitable for smoke detector tester 805582.

Technical Data

Content	250 ml (per bottle)
---------	---------------------



Not suitable for Series 9000, 9100 and 9200 ionization smoke detectors.
Please take note that this item has to be handled as dangerous goods (aerosols, non-flammable, UN1950)

805583

**CO test gas for smoke detector tester 805582**

Test gas for testing carbon monoxide CO-detectors. Specifically designed for the OTG multisensor (CO) IQ8Quad 802473, suitable for smoke detector tester 805582.

Technical Data

Content	250 ml (per bottle)
---------	---------------------



The OTG multisensor detector (CO) IQ8Quad (part no. 802473) should only be tested in connection with test gas 060430.10 suitable for smoke detector tester 805582. Detector 802473 has been approved as smoke detector by VdS and the CO test gas is used to additionally trigger the electrochemical CO-gas cell.
Please take note that this item has to be handled as dangerous goods (aerosols, non-flammable, UN1950)